

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. TC9964240000000624F

Dated: 27/04/2024

It is certified that an inspection team headed by NAVEEN KUMAR SURI ( SAMPLING ASSI.) (Name of Officers with designation) from UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY inspected the J AND A INTERNATIONAL SCHOOL, SHERGARH ROAD, BAHERI BAREILLY, UTTAR PRADESH on 25/04/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. LAB/BLY/2024-25/624 dated 27/04/2024 Of UTTAR PRADESH JAL NIGAM (RURAL), BAREILLY (PHED Lab) certified that the J AND A INTERNATIONAL SCHOOL, SHERGARH ROAD, BAHERI BAREILLY, UTTAR PRADESH has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms Prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 27/04/2024 to 26/04/2025

Signature with Seal: .....  
Name : .....  
Designation : .....  
Name & Address of the Office / Department : .....

Vipin Kumar Singh  
Assistant Engineer  
U.P. Jal Nigam, Bareilly (R)

To



MANAGER

J AND A INTERNATIONAL  
SCHOOL, SHERGARH ROAD,  
BAHERI BAREILLY, UTTAR  
PRADESH

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies





		Analysis Report					
		District Level Water Analysis Laboratory U.P. Jal Nigam (RURAL)					
		Near M.B. Inter Collage, Gandhi Nagar, Bareilly (U.P.)					
Customer Details							
Office Name and Address		J AND A INTERNATIONAL SCHOOL , SHERGARH , BAREILLY					
Ref Letter No & Date		0,		DATE - 27.04.2024		Report No.- LA8/BLY/2024-25/624	
Basic details of sample							
District	BAREILLY	Tehseel	BAHERI		Analysis Start Date	27.04.2024	
Village/G.P./Area	BAHERI	Block	BAHERI		Analysis Completion Date	29.04.2024	
Habitation	BAHERI	Location	IN SCHOOL CAMPUS		Report Issue Date	29.04.2024	
Water Source	Submersible	Sample Code	PS- 624		Sample Depositor	Rakesh	
Quantity of Sample	1 ltr	Date of Sample Collection	27.04.2024				
Receiving Date	27.04.2024	Sample Collector	VIPIN KUMAR				
Environmental Condition							
Temperature		27°C		Humidity		54%	
Technical Data of Analysis							
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis	
				Acceptable Limit	Permissible Limit		
1	2	3	4	5	6	7	
1	Colour	(Hazen)	0	5	15	IS 3025 (Part 4):2021	
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022	
4	Turbidity	(NTU)	0.34	1.00	5.00	IS 3025 (Part 10) : 2022	
5	TDS	(mg/L)	201	500	2000	IS 3025 (Part 16) : 2022	
6	PH	-	7.73	6.5-8.5	6.5-8.5	IS 3025 (Part 11) : 2022	
7	Iron	(mg/L)	0.2	1.00	1.00	IS:3025(Part-53):2014	
8	Sulphate	(mg/L)	9.3	200	400	IS 3025 (Part 24) : 2022	
9	Alkalinity	(mg/L)	170	200	600	IS 3025 (Part 23) : 2019	
10	Hardness	(mg/L)	168	200	600	IS 3025 (Part 21) : 2019	
11	Chloride	(mg/L)	10	250	1000	IS 3025 (Part 32) : 2019	
12	Calcium	(mg/L)	64	75	200	IS:3025(Part-40):2019	
13	Magnesium	(mg/L)	25.2	30	100	APHA 24th Edition 3500Mg Method B	
Note							
1. This Certificate refers only to the particular sample(s) submitted for testing.							
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.							
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.							
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.							

Page no:-1/1

Email - anamika05anu@gmail.com  
U.P.J.N.BAREILLY (RURAL) Cont.No:- 7318251236

Prepared By  
अनिल कुमार  
गुणवत्ता प्रबन्धक  
जल विश्लेषण प्रयोगशाला  
उ० प्र० जल निगम बरेली (ग्रामीण)

END OF THE REPORT

Authorised signatory

अनामिका सिंह  
तकनीकी प्रबन्धक  
जल विश्लेषण प्रयोगशाला  
उ० प्र० जल निगम, बरेली (ग्रामीण)

